

## EÚ – DECLARATION OF CONFORMITY

**Name of organisation:** KIWA sk, s.r.o.  
**Address:** Krivánska 5, 949 01 Nitra  
**CRN:** 44 769 512  
**Manufacturer:** KIWA sk, s.r.o. Slovak Republic  
**Address:** Jakuba Haška 1, 949 01 Nitra  
**Establishment:** Jakuba Haška 1, 949 01 Nitra

**Brand:** **KIWA®**  
**Models:** SPD modules PODA-275 230V and POD275S 230V  
**Type:** SPD KIWA type3 - Surge Protective Devices KIWA type 3

**Description of goods:**

The surge protection device (SPD) is an electrical equipment for protection of the electrical circuit and installation system. Location nearby protected equipment - type 3

The above designated products have been assessed according to the § 23 Sect. 1 Act No. 56/2018 Coll. and they comply with technical requirement of the following statutory decrees:

**Number:** 148/2016 Coll. for Low Voltage (LVD 2014/35/EU)  
**Title:** Statutory Decree on Technical requirements and Processes of Assessment of Conformity for Electrical Equipment used in Certain Range of Voltage  
**Number:** 127/2016 Coll. for ECM (ECM 2014/30/EU)  
**Title:** Statutory Decree on Technical requirements for Products in terms of Electromagnetic Compatibility

This Declaration of Conformity is issued under the responsibility of the manufacturer.

**Essential technical Data:**

**PODA-275 230V**  $U_n = 230 \text{ V AC}$ ,  $I_{SN} = 2,5 \text{ kA (8/20)}$ ,  $U_p \text{ (L-N)} \leq 0,9 \text{ kV}$ ,  $U_p \text{ (L-PE)} \leq 1,5 \text{ kV}$ ,  
 $U_p \text{ (N-PE)} \leq 1,2 \text{ kV}$ ,  $U_{oc} = 3 \text{ kV}$ , IP 20

**POD-275S 230V**  $U_n = 230 \text{ V AC}$ ,  $I_{SN} = 2,5 \text{ kA (8/20)}$ ,  $U_p \text{ (L-N)} \leq 0,9 \text{ kV}$ ,  $U_p \text{ (L-PE)} \leq 1,5 \text{ kV}$ ,  
 $U_p \text{ (N-PE)} \leq 1,2 \text{ kV}$ ,  $U_{oc} = 3 \text{ kV}$ , IP 20

Full specifications are listed in the KIWA catalogue

The following technical standards were used at assessment of compliance:

STN EN 60664-1:2004-07 (33 0420)

STN 34 5615: 1984 + A1: 1986 + Z1:1997

European Standards: EN 61643-11, VDE 0675-6: 1989 International Standards: IEC 61643-11:2011

Authorised person (AP) identification: EVPÚ a.s. – SKTC-101

Address: Trenčianska 19

Nová Dubnica 018 51, Slovenská republika

Certificate Number: 00413/101/1/2008

Date of issue: 02.10.2008

Conformity assessment has been executed in accordance with directives of the EP and Council

and the mark **CE** may be used.

Year of CE marking (Low voltage directive): March 2008

**Declared by:**

Name: Ing. Daniel Sidun

Date: 18<sup>th</sup> May 2017

Position: Executive Director

Signature:

Address: Nitra

*Daniel Sidun*  
**KIWA sk, s.r.o.**  
Krivánska 5  
949 01 Nitra