

EÚ – DECLARATION OF CONFORMITY

Name of organisation: KIWA sk, s.r.o.
Address: Krivánska 5, 949 01 Nitra
CRN: 44 769 512
Manufacturer: KIWA sk, s.r.o. Slovak Republic
Address: Jakuba Haška 1, 949 01 Nitra
Establishment: Jakuba Haška 1, 949 01 Nitra

Brand: **KIWA®**
Models: ZPO D LMO1 iS-3kV
Type: SPD KIWA type3 – Overvoltage protection sockets KIWA type 3

Description of goods:

The surge protection device (SPD) is an electrical equipment for protection of the electrical circuit and installation system. Location nearby protected equipment - type 3

The above designated products have been assessed according to the § 23 Sect. 1 Act No. 56/2018 Coll. and they comply with technical requirement of the following statutory decrees:

Number: 148/2016 Coll. for Low Voltage (LVD 2014/35/EU)
Title: Statutory Decree on Technical requirements and Processes of Assessment of Conformity for Electrical Equipment used in Certain Range of Voltage
Number: 127/2016 Coll. for ECM (ECM 2014/30/EU)
Title: Statutory Decree on Technical requirements for Products in terms of Electromagnetic Compatibility

This Declaration of Conformity is issued under the responsibility of the manufacturer.

Essential technical Data:

ZPO D LMO1 iS-3kV $U_n = 230 \text{ V AC}$, $I_{SN} = 2,5 \text{ kA (8/20)}$, $U_p \text{ (L-N)} \leq 0,9 \text{ kV}$, $U_p \text{ (L-PE)} \leq 1,5 \text{ kV}$,
 $U_p \text{ (N-PE)} \leq 1,2 \text{ kV}$, $U_{oc} = 3 \text{ kV}$, IP 20

Full specifications are listed in the KIWA catalogue

The following technical standards were used at assessment of compliance:

STN EN 60664-1:2004-07 (33 0420)
STN 34 5615: 1984 + A1: 1986 + Z1:1997
European Standards: EN 61643-11:2012, VDE 0675-6: 1989
International Standards: IEC 61643-11:2011
Authorised person (AP) identification: EVPÚ a.s. – SKTC-101
Address: Trenčianska 19
Nová Dubnica 018 51, Slovenská republika

Certificate Number: 00470/101/1/2005
Date of issue: 21.10.2005

Conformity assessment has been executed in accordance with directives of the EP and Council

and the mark **CE** may be used.

Year of CE marking (Low voltage directive): March 2007

Declared by:

Name: Ing. Daniel Sidun
Position: Executive Director
Address: Nitra

Date: 18th May 2017

Signature:

Daniel Sidun
KIWA sk, s.r.o.
Krivánska 5
949 01 Nitra